

January 19, 2018

Ms. Patrick Paine, E.I.  
City of Raleigh Public Utilities Department  
One Exchange Plaza, Suite 620  
Raleigh, NC 27601

**RE: Wendell Falls – Phase 6B Comments**

Mr. Paine,

Based on redline plans received, we offer the following responses:

**Sheet 2.0:**

- “City of Raleigh Waterline Easement” note has been updated.

**Sheet C4.1:**

- Note for SSMH-6B-14A updated to specify 5’ diameter manhole with extended base.
- Existing manhole label updated to read “PROPOSED”.

**Sheet C4.2:**

- Label has been added to specify size of existing main along Underhill Road.
- Label has been added to describe the connection between the existing and proposed water main.

**Sheet C4.3:**

- A label showing the size of the existing connection along Big Falls Dr. has been added.

**Sheet C4.7:**

- City of Raleigh Public Sewer Collection/Extension System permit authorization block has been added.
- SSMH-6B-21 & SSMH-6B-22 have been revised to specify 5’ diameter manholes.

Venture IV Building

1730 Varsity Drive

Raleigh, NC 27606

919.233.8091

Fax 919.233.8031

www.mckimcreed.com

Sincerely,

McKIM & CREED, INC.

*Gareth Avant*

Gareth Avant, PE, LEED AP  
Project Engineer

cc: Project File