



Fire Services

TEL 919 856 6340
FAX 919 856 6236

331 S. McDowell St., P.O. Box 550, Raleigh, NC 27602
www.wakegov.com

Permit #: **WF-SF13**

Friday July 31, 2015

Subdivision/Wendell Falls
WENDELL FALLS PKY
Wendell, NC 27591

The plans that were submitted for the above referenced project were reviewed on Friday July 31, 2015. They were reviewed for compliance with applicable requirements of the North Carolina Fire Code and other referenced standards. Comments from this review are provided below and these items must be addressed before final approval.

Please contact the Deputy Fire Marshal listed below if you have any questions concerning this review.

Review Comments (sorted by Code Section)

503.2.5 Dead ends

Dead-end fire apparatus access roads in excess of 150 feet (45 720 mm) in length shall be provided with an approved area for turning around fire apparatus.

Stub streets at the end of Mill Station Lane and Road D exceed 150 feet. Either shorten these stubs to not exceed 150 feet or install a turn around in accordance with Appendix D (2012 NCFC).

9999.2 Notes

Show Fire Hydrant locations on plans.

503.2.4 Turning radius

The required turning radius of a fire apparatus access road shall be determined by the fire code official.

It is recommended that the Wendell Fire Chief verify that the turning radius is adequate at all intersections.

Permit #: **WF-SF13**

Sincerely,

Tanner, J. Braxton