

Contact: Chris Doherty
Franklin Co. Public Utilities
Phone: (919) 556-6177
Fax: (919) 556-6709

1630 US Highway #1
Youngsville, NC 27596
www.franklincountync.us

FRANKLIN COUNTY

PRESS RELEASE

Notification of Discharge of Untreated Wastewater

General Statute 143-215.1C requires that the owner or operator of any wastewater collection or treatment works to issue a press release when an untreated wastewater discharge of 1,000 gallons or more reaches surface waters.

In accordance with that regulation, the following news release has been prepared and issued to media in the affected county: Franklin

Franklin County Public Utilities experienced a discharge of untreated wastewater from the Youngsville Regional pump station in Youngsville. The spill was a result of rain on Friday, December 28, 2018. The spill occurred at 4:00 PM on December 28, 2018 and discharged until 6:00 PM on December 28, 2018. The discharge of wastewater was estimated to be 3,600 gallons and it entered into an unnamed tributary of Richland Creek which is a tributary of the Neuse River Basin. Franklin County Public Utilities staff was dispatched to the site and started clean up after the overflow stopped.

The division of Water Quality was notified of these events on December 29, 2018 and is reviewing the matter. For additional information concerning this event, please contact Chris Doherty, Franklin County Public Utilities Director at (919) 556-6711. Additional information can be obtained by visiting Franklin County's website at www.franklincountync.us and our Facebook Page, search Franklin County Public Utilities.

Franklin County Government is committed to effective and innovative public services for all Franklin County citizens and businesses.