

Contact: Chris Doherty
Franklin Co. Public Utilities
Phone: (919) 556-6177
Fax: (919) 556-6709

1630 US Highway #1
Youngsville, NC 27596
www.franklincountync.us

FRANKLIN COUNTY

FOR IMMEDIATE RELEASE, SEPTEMBER 1, 2020

PRESS RELEASE

Notification of Discharge of Untreated Wastewater

General Statute 143-215.1C requires that the owner or operator of any wastewater collection or treatment works to issue a press release when an untreated wastewater discharge of 1,000 gallons or more reaches surface waters.

In accordance with that regulation, the following news release has been prepared and issued to media in the affected county: Franklin

Franklin County Public Utilities experienced a discharge of untreated wastewater from the Youngsville Regional pump station in Youngsville. The discharge was a result of heavy rain on Monday, August 31, 2020. The discharge started at 11:00 PM and continued until Tuesday, September 1, 2020 at 2:00 AM. The discharge of wastewater was estimated to be 11,560 gallons and approximately 6,200 gallons entered into an unnamed tributary of Richland Creek which is a tributary of the Neuse River Basin. Franklin County Public Utilities staff was dispatched to the site and started clean up after the discharge stopped.

The Division of Water Quality was notified of this event on September 1, 2020 and is reviewing the matter. For additional information concerning this event, please contact Franklin County Public Utilities Department at (919) 556-6177. Additional information can be obtained by visiting Franklin County's website at www.franklincountync.us.

Franklin County Government is committed to effective and innovative public services for all Franklin County citizens and businesses.

END